



गण्डकी बोर्डिंग स्कूल GANDAKI BOARDING SCHOOL

(National School)
Lamachaur, Pokhara -16, Nepal

☎ 00977-61-443398, 443414, 444719
✉ P.O. Box No.9
✉ Email: info@gbs.edu.np
🌐 www.gbs.edu.np

Date: 2082/01/21

QUOTATION

Please provide your best offer (quotation) for the supply of following items on or before 30th of Baishak to the school. You are especially requested to specification with unit price for the items stated below:

Supply and Installation of Chiller Room	
01	<p>Chiller Room For Kitchen Utility Size: 12*12*8 Feet No of Chamber: 1 Insulation Section Wall/Ceiling: Puff Panel 0MM/PPGI/PPGI Type: Cam Lock Floor: Puff Slab 60MM + 2mm Tart felt Blanket+2.5 Inch PCC Customer Scope Door: Swing Type 2.8*6.5 Feet With Installation Material Fleshing, U Chancel, Pop Rivet and sealant</p> <p>Refrigeration Section Temperature Range: up to 2°C No of Unit: 1 Capacity: 4.5 KW Cooling Capacity @ -4° Evaporative Temperature and 54° Condenser Temperature Compressor: Emerson CR30 Compressor Type: Reciprocating Evaporator: 3 Fan Full Stainless-Steel Body Fins and Tube: Aluminum and Copper Power: 280-440V-50Hz Evaporator Canopy: Stainless Steel Refrigerant: R407 CFC Free Temperature Control: Digital Electrical Panel: Inbuilt with Unit</p>

- **Installation & Testing:** The supplier must install the unit on-site, conduct necessary testing, and hand over the fully functional system.
- **Product & Documentation:** The supplier must provide the product along with the official manufacturer's catalog and ensure service availability in Pokhara Valley.
- **Authorization Letter:** The supplier must submit an authorization letter from the manufacturer, certifying them as an authorized dealer and importer of the product for Nepal.
- Quotation Will Be disqualified if proper Specification /Model no is clearly mentioned
- The Quotation Providers must specify their terms and condition regarding Guarantee and warranty.
- The supplier must submit firms registration and tax clearance certificate 2080/81.

Dr. Bishwo Udhir Poudel Gharti
Principal

